



September 15, 2022

Brent Paul, Director of Facility Operations
Lake Oswego School District
2455 Country Club Road
Lake Oswego, Oregon 97034

Via email: paulb@loswego.k12.or.us

Regarding: Radon Testing
Lakeridge Junior High School
4700 Jean Road
Lake Oswego, Oregon 97035
PBS Project 21600.051

Dear Mr. Paul:

From April 4 to April 6, 2022, PBS Engineering and Environmental Inc. (PBS) performed short-term radon testing at Lakeridge Middle School located at 4700 Jean Road in Lake Oswego, Oregon.

The Environmental Protection Agency (EPA) and Oregon Health Authority (OHA) recommend that buildings be tested for radon and that any radon concentrations be maintained below 4.0 picocuries per liter (pCi/L) of air.

PBS used Radonova brand activated charcoal adsorption detector short-term radon test kits to measure radon levels in frequently occupied rooms that are in contact with the ground or above unoccupied basements or crawl spaces. The test kits were shipped under chain-of-custody to Alpha Energy Laboratories (National Radon Proficiency Program ID: 101132 AL) for analysis.

Laboratory results indicated that all short-term radon tests at Lakeridge Middle School were below 4.0 pCi/L.

See the attached laboratory analysis report for sample locations and additional details.

In addition to the EPA recommendation that radon concentrations do not exceed 4.0 pCi/L, OHA recommends that the following steps be conducted based on the results of a room's initial short-term test:

- **If the result is less than 2.0 pCi/L**, school districts are required to test again every 10 years, per Oregon Revised Statute 332.166-167.
- **If the result is between 2.0 pCi/L and 4.0 pCi/L**, consider fixing (i.e., lowering) the radon in that room.
- **If the result is from 4.0 pCi/L to 8.0 pCi/L**, perform a follow-up measurement of that room using a long-term test. This test should be conducted over as much of a nine-month school year as possible, when the room is likely to be occupied. If that result is equal to or greater than 4.0 pCi/L, the radon in the room should be fixed (i.e., lowered).

- **If the initial short-term test result is equal to or greater than 8.0 pCi/L**, conduct a second short-term test and average its result with the initial short-term test result. If the average of the two is equal to or greater than 4.0 pCi/L, radon in the room should be fixed (i.e., lowered).

Note: A great difference in the results of the short-term tests may indicate a flaw in the testing process. Investigate and consider retesting. For situations in which one of the test results is equal to or greater than 4.0 pCi/L, if the higher result is two or more times the lower result, repeat the test.

LIMITATIONS OF SCOPE

This study was limited to the tests and locations as previously indicated. The site as a whole may have other environmental concerns that will not be characterized by this study. The findings and conclusions of this work are not scientific certainties, but probabilities based on professional judgment concerning the significance of the data gathered during the course of this investigation. PBS is not able to represent conditions on the site or adjoining sites beyond those detected or observed by PBS.

Please feel free to contact me at 503.417.7607 or bob.kleckner@pbsusa.com with any questions or comments.


Sincerely,

Bob Kleckner
Sr. Project Manager

Attachment: Floor Plan
Radonova Laboratory Analysis Radon Monitoring Report

1. THIS DRAWING IS DIAGRAMMATIC. IT IS FOR GENERAL INFORMATION AND SAMPLE LOCATIONS.

● 110 RADON TEST AND KIT NUMBER



HAZARDOUS MATERIAL SURVEY PLAN
LAKERIDGE JUNIOR HIGH SCHOOL
4700 JEAN ROAD, LAKE OSWEGO, OREGON

[illegible]

| |
|------------------------------|
| DRAWN BY JAB |
| CHECKED: BK |
| DATE: MAY 2022 |
| PROJECT NUMBER: 21600.051 |
| SHEET DRAWING NO: |
| RA13 |
| SHEET 13 OF 18 |

PBS Portland
4321 S Corbett Ave

BY
PBS Engineering & Environmental

REPORT RECEIVER(S)
alex.johnson@pbsusa.com;lindsey.peterson@pbsusa.com
PBS Portland

RADON MONITORING REPORT

Description of the measurement

The measurement was performed with an Activated Charcoal Adsorption detector (QuickScreen) and was analyzed by Alpha Energy Laboratories (NRPP ID: 101132 AL).

The detector(s) arrived to Alpha Energy Laboratories, Inc. **04/12/2022**.
They were measured **04/12/2022**.

Test data have been given by PBS Portland

Property data and address

MEASURE SITE ADDRESS
Lakeridge MS
4700 Jean Road
Lake Oswego OR

BUILDING ID

Test results

| DETECTOR | MEASUREMENT PERIOD | DESCRIPTION / LOCATION | FLOOR | RADON RESULT |
|------------------------|---|--|-------|--------------|
| RK109587 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 02:56 PM | "by desk window sill, inside window, N108" | First | 0.8 pCi/L |
| RK110390 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 02:59 PM | by desk window sill, N107 | First | < 0.7 pCi/L |
| RK109579 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 02:59 PM | "office, next to mini fridge", N107A | First | < 0.9 pCi/L |
| RK109613 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 02:59 PM | "quiet room, on desk", N107B | First | < 0.9 pCi/L |
| RK110431 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 02:57 PM | paper towel holder, N110 | First | < 1.0 pCi/L |
| RK109861 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 02:57 PM | paper towel holder, N109 | First | < 0.7 pCi/L |
| RK110392 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 01:05 PM | paper towel holder, N112 | First | < 0.8 pCi/L |

Comment to the results

This report replaces 6352561:2. Reason: new or corrected measurement information has been received.

Trygve Rönqvist (Electronically signed)

Signature Radonova Laboratories Laboratory Measurement Specialist

This report may only be reproduced in full, unless issuing laboratory has given prior written approval.

DISCLAIMER

Radonova Inc. makes no warranty of any kind, express or implied, as regard to the use, operation or analysis of any Radonova Inc. monitor. Radonova Inc. specifically disclaims implied warranties of merchantability and fitness for a particular purpose. Radonova Inc. is not responsible for any damage, including consequential damages, to persons or property resulting from the use of the monitor or the resulting data.

RADONOVA INC.

1 EAST 22nd STREET, SUITE 200
LOMBARD, IL 60148
331.814.2200, help@radonova.com

PBS Portland
4321 S Corbett Ave

OWN ID
N/A
BY
PBS Engineering & Environmental

REPORT RECEIVER(S)
alex.johnson@pbsusa.com;lindsey.peterson@pbsusa.com
PBS Portland

RADON MONITORING REPORT

Description of the measurement

The measurement was performed with an Activated Charcoal Adsorption detector (QuickScreen) and was analyzed by Alpha Energy Laboratories (NRPP ID: 101132 AL).

The detector(s) arrived to Alpha Energy Laboratories, Inc. **04/12/2022**.
They were measured **04/12/2022**.

Test data have been given by PBS Portland

Property data and address

MEASURE SITE ADDRESS
Lakeridge MS
4700 Jean Road
Lake Oswego OR

BUILDING ID

| DETECTOR | MEASUREMENT PERIOD | DESCRIPTION / LOCATION | FLOOR | RADON RESULT |
|------------------------|---|---|-------|--------------|
| RK110457 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 03:03 PM | paper towel holder, N114 | First | < 0.8 pCi/L |
| RK110438 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 03:00 PM | paper towel holder, N111 | First | < 0.9 pCi/L |
| RK110299 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 03:04 PM | paper towel holder, N113 | First | < 1.0 pCi/L |
| RK110321 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 03:06 PM | top of announcement box, N115 | First | < 0.9 pCi/L |
| RK110290 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 03:07 PM | on inside window sill, N117 | First | < 0.8 pCi/L |
| RK110437 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 03:07 PM | on desk under TV, N117A | First | < 0.8 pCi/L |
| RK110305 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 03:08 PM | on high cabinet next to announcemen, W101 | First | < 0.8 pCi/L |
| RK110353 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 03:10 PM | high on cabinet next to sink, W103 | First | < 0.8 pCi/L |

Comment to the results

This report replaces 6352561:2. Reason: new or corrected measurement information has been received.

Trygve Rönqvist (Electronically signed)

Signature Radonova Laboratories Laboratory Measurement Specialist

This report may only be reproduced in full, unless issuing laboratory has given prior written approval.

DISCLAIMER

Radonova Inc. makes no warranty of any kind, express or implied, as regard to the use, operation or analysis of any Radonova Inc. monitor. Radonova Inc. specifically disclaims implied warranties of merchantability and fitness for a particular purpose. Radonova Inc. is not responsible for any damage, including consequential damages, to persons or property resulting from the use of the monitor or the resulting data.

RADONOVA INC.

1 EAST 22nd STREET, SUITE 200
LOMBARD, IL 60148
331.814.2200, help@radonova.com

PBS Portland
4321 S Corbett Ave

OWN ID
N/A
BY
PBS Engineering & Environmental

REPORT RECEIVER(S)
alex.johnson@pbsusa.com;lindsey.peterson@pbsusa.com
PBS Portland

RADON MONITORING REPORT

Description of the measurement

The measurement was performed with an Activated Charcoal Adsorption detector (QuickScreen) and was analyzed by Alpha Energy Laboratories (NRPP ID: 101132 AL).

The detector(s) arrived to Alpha Energy Laboratories, Inc. **04/12/2022**.
They were measured **04/12/2022**.

Test data have been given by PBS Portland

Property data and address

MEASURE SITE ADDRESS
Lakeridge MS
4700 Jean Road
Lake Oswego OR

BUILDING ID

| DETECTOR | MEASUREMENT PERIOD | DESCRIPTION / LOCATION | FLOOR | RADON RESULT |
|------------------------|---|---|-------|--------------|
| RK110309 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 03:10 PM | "music office, on inside window sil, W105 | First | < 0.7 pCi/L |
| RK110333 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 03:10 PM | "music office, on inside window sil, W105 | First | < 0.7 pCi/L |
| RK110317 [QuickScreen] | 04/04/2022 07:03 AM – 04/06/2022 03:11 PM | high on cabinet next to sink, W107 | First | < 0.9 pCi/L |
| RK110324 [QuickScreen] | 04/04/2022 07:26 AM – 04/06/2022 03:17 PM | "practice room, on inside window si, W103A1 | First | < 0.8 pCi/L |
| RK110342 [QuickScreen] | 04/04/2022 07:26 AM – 04/06/2022 03:17 PM | "practice room, on inside window si, W103A2 | First | < 0.9 pCi/L |
| RK110277 [QuickScreen] | 04/04/2022 07:26 AM – 04/06/2022 03:17 PM | "practice room, on inside window si, W103A3 | First | < 0.9 pCi/L |
| RK110274 [QuickScreen] | 04/04/2022 07:26 AM – 04/06/2022 03:13 PM | on paper towel holder, S117 | First | 1.0 pCi/L |
| RK110291 [QuickScreen] | 04/04/2022 07:26 AM – 04/06/2022 03:14 PM | on paper towel holder, S112 | First | 1.8 pCi/L |

Comment to the results

This report replaces 6352561:2. Reason: new or corrected measurement information has been received.

Trygve Rönqvist (Electronically signed)

Signature Radonova Laboratories Laboratory Measurement Specialist

This report may only be reproduced in full, unless issuing laboratory has given prior written approval.

DISCLAIMER

Radonova Inc. makes no warranty of any kind, express or implied, as regard to the use, operation or analysis of any Radonova Inc. monitor. Radonova Inc. specifically disclaims implied warranties of merchantability and fitness for a particular purpose. Radonova Inc. is not responsible for any damage, including consequential damages, to persons or property resulting from the use of the monitor or the resulting data.

RADONOVA INC.

1 EAST 22nd STREET, SUITE 200
LOMBARD, IL 60148
331.814.2200, help@radonova.com

PBS Portland
4321 S Corbett Ave

OWN ID
N/A
BY
PBS Engineering & Environmental

REPORT RECEIVER(S)
alex.johnson@pbsusa.com;lindsey.peterson@pbsusa.com
PBS Portland

RADON MONITORING REPORT

Description of the measurement

The measurement was performed with an Activated Charcoal Adsorption detector (QuickScreen) and was analyzed by Alpha Energy Laboratories (NRPP ID: 101132 AL).

The detector(s) arrived to Alpha Energy Laboratories, Inc. **04/12/2022**.
They were measured **04/12/2022**.

Test data have been given by PBS Portland

Property data and address

MEASURE SITE ADDRESS
Lakeridge MS
4700 Jean Road
Lake Oswego OR

BUILDING ID

| DETECTOR | MEASUREMENT PERIOD | DESCRIPTION / LOCATION | FLOOR | RADON RESULT |
|------------------------|---|---|-------|--------------|
| RK110350 [QuickScreen] | 04/04/2022 07:26 AM – 04/06/2022 03:15 PM | on paper towel holder, S108 | First | < 0.8 pCi/L |
| RK110283 [QuickScreen] | 04/04/2022 07:26 AM – 04/06/2022 03:20 PM | on paper towel holder, S106 | First | < 0.8 pCi/L |
| RK110335 [QuickScreen] | 04/04/2022 07:26 AM – 04/06/2022 03:20 PM | on paper towel holder, S106 | First | < 0.9 pCi/L |
| RK110358 [QuickScreen] | 04/04/2022 07:26 AM – 04/06/2022 03:20 PM | on paper towel holder, S107 | First | < 0.8 pCi/L |
| RK110329 [QuickScreen] | 04/04/2022 07:26 AM – 04/06/2022 03:21 PM | "science storage, on paper towel ho, S105 | First | < 0.9 pCi/L |
| RK110328 [QuickScreen] | 04/04/2022 07:26 AM – 04/06/2022 03:21 PM | "science storage, on paper towel ho, S104 | First | < 0.8 pCi/L |
| RK110332 [QuickScreen] | 04/04/2022 07:45 AM – 04/06/2022 03:22 PM | on paper towel holder, S102 | First | < 1.0 pCi/L |
| RK110325 [QuickScreen] | 04/04/2022 07:45 AM – 04/06/2022 03:22 PM | on paper towel holder, S103 | First | 1.0 pCi/L |

Comment to the results

This report replaces 6352561:2. Reason: new or corrected measurement information has been received.

Trygve Rönqvist (Electronically signed)

Signature Radonova Laboratories Laboratory Measurement Specialist

This report may only be reproduced in full, unless issuing laboratory has given prior written approval.

DISCLAIMER

Radonova Inc. makes no warranty of any kind, express or implied, as regard to the use, operation or analysis of any Radonova Inc. monitor. Radonova Inc. specifically disclaims implied warranties of merchantability and fitness for a particular purpose. Radonova Inc. is not responsible for any damage, including consequential damages, to persons or property resulting from the use of the monitor or the resulting data.

RADONOVA INC.

1 EAST 22nd STREET, SUITE 200
LOMBARD, IL 60148
331.814.2200, help@radonova.com

PBS Portland
4321 S Corbett Ave

OWN ID
N/A
BY
PBS Engineering & Environmental

REPORT RECEIVER(S)
alex.johnson@pbsusa.com;lindsey.peterson@pbsusa.com
PBS Portland

RADON MONITORING REPORT

Description of the measurement

The measurement was performed with an Activated Charcoal Adsorption detector (QuickScreen) and was analyzed by Alpha Energy Laboratories (NRPP ID: 101132 AL).

The detector(s) arrived to Alpha Energy Laboratories, Inc. **04/12/2022**.
They were measured **04/12/2022**.

Test data have been given by PBS Portland

Property data and address

MEASURE SITE ADDRESS
Lakeridge MS
4700 Jean Road
Lake Oswego OR

BUILDING ID

| DETECTOR | MEASUREMENT PERIOD | DESCRIPTION / LOCATION | FLOOR | RADON RESULT |
|------------------------|---|--|-------|--------------|
| RK110308 [QuickScreen] | 04/04/2022 07:45 AM – 04/06/2022 03:22 PM | on paper towel holder, S101 | First | < 0.8 pCi/L |
| RK110300 [QuickScreen] | 04/04/2022 07:45 AM – 04/06/2022 03:23 PM | "custodial office, top of black tal, E118A | First | < 0.7 pCi/L |
| RK109630 [QuickScreen] | 04/04/2022 07:45 AM – 04/06/2022 03:23 PM | on desk, Kitchen office | First | < 0.9 pCi/L |
| RK110284 [QuickScreen] | 04/04/2022 07:45 AM – 04/06/2022 03:23 PM | paper towel holder, Kitchen main | First | < 1.1 pCi/L |
| RK110316 [QuickScreen] | 04/04/2022 07:45 AM – 04/06/2022 03:34 PM | "gym, wifi router box", E122 | First | < 0.8 pCi/L |
| RK109857 [QuickScreen] | 04/04/2022 07:45 AM – 04/06/2022 03:28 PM | "girls P.E. office, inside window s, E123A | First | < 0.7 pCi/L |
| RK109622 [QuickScreen] | 04/04/2022 07:45 AM – 04/06/2022 03:29 PM | "boys P.E. office, inside window si, E129A | First | < 0.7 pCi/L |
| RK110435 [QuickScreen] | 04/04/2022 07:45 AM – 04/06/2022 03:30 PM | "gym, on bleachers", E120 | First | < 0.7 pCi/L |

Comment to the results

This report replaces 6352561:2. Reason: new or corrected measurement information has been received.

Trygve Rönqvist (Electronically signed)

Signature Radonova Laboratories Laboratory Measurement Specialist

This report may only be reproduced in full, unless issuing laboratory has given prior written approval.

DISCLAIMER

Radonova Inc. makes no warranty of any kind, express or implied, as regard to the use, operation or analysis of any Radonova Inc. monitor. Radonova Inc. specifically disclaims implied warranties of merchantability and fitness for a particular purpose. Radonova Inc. is not responsible for any damage, including consequential damages, to persons or property resulting from the use of the monitor or the resulting data.

RADONOVA INC.

1 EAST 22nd STREET, SUITE 200
LOMBARD, IL 60148
331.814.2200, help@radonova.com

PBS Portland
4321 S Corbett Ave

OWN ID
N/A
BY
PBS Engineering & Environmental

REPORT RECEIVER(S)
alex.johnson@pbsusa.com;lindsey.peterson@pbsusa.com
PBS Portland

RADON MONITORING REPORT

Description of the measurement

The measurement was performed with an Activated Charcoal Adsorption detector (QuickScreen) and was analyzed by Alpha Energy Laboratories (NRPP ID: 101132 AL).

The detector(s) arrived to Alpha Energy Laboratories, Inc. **04/12/2022**.
They were measured **04/12/2022**.

Test data have been given by PBS Portland

Property data and address

MEASURE SITE ADDRESS
Lakeridge MS
4700 Jean Road
Lake Oswego OR

BUILDING ID

| DETECTOR | MEASUREMENT PERIOD | DESCRIPTION / LOCATION | FLOOR | RADON RESULT |
|---------------------------|---|--|-------|--------------|
| RK110449 [QuickScreen] | 04/04/2022 08:06 AM – 04/06/2022 03:27 PM | under microwave, East commons/cafeteria area | First | < 0.7 pCi/L |
| RK109836 [QuickScreen] | 04/04/2022 08:06 AM – 04/06/2022 03:27 PM | on paper towel holder, Stage E112 | First | < 0.8 pCi/L |
| RK109827 [QuickScreen] | 04/04/2022 08:06 AM – 04/06/2022 02:37 PM | top of AED case, West commons | First | < 0.8 pCi/L |
| RK109819 [QuickScreen] | 04/04/2022 08:09 AM – 04/06/2022 02:37 PM | top of AED case, West commons | First | < 1.0 pCi/L |

Comment to the results

This report replaces 6352561:2. Reason: new or corrected measurement information has been received.

Trygve Rönqvist (Electronically signed)

Signature Radonova Laboratories Laboratory Measurement Specialist

This report may only be reproduced in full, unless issuing laboratory has given prior written approval.

DISCLAIMER

Radonova Inc. makes no warranty of any kind, express or implied, as regard to the use, operation or analysis of any Radonova Inc. monitor. Radonova Inc. specifically disclaims implied warranties of merchantability and fitness for a particular purpose. Radonova Inc. is not responsible for any damage, including consequential damages, to persons or property resulting from the use of the monitor or the resulting data.

RADONOVA INC.

1 EAST 22nd STREET, SUITE 200
LOMBARD, IL 60148
331.814.2200, help@radonova.com

PBS Portland
4321 S Corbett Ave

OWN ID
N/A
BY
PBS Engineering & Environmental

REPORT RECEIVER(S)
alex.johnson@pbsusa.com;lindsey.peterson@pbsusa.com
PBS Portland

RADON MONITORING REPORT

Description of the measurement

The measurement was performed with an Activated Charcoal Adsorption detector (QuickScreen) and was analyzed by Alpha Energy Laboratories (NRPP ID: 101132 AL).

The detector(s) arrived to Alpha Energy Laboratories, Inc. **04/12/2022**.
They were measured **04/12/2022**.

Test data have been given by PBS Portland

Property data and address

MEASURE SITE ADDRESS
Lakeridge MS
4700 Jean Road
Lake Oswego OR

BUILDING ID

| DETECTOR | MEASUREMENT PERIOD | DESCRIPTION / LOCATION | FLOOR | RADON RESULT |
|---------------------------|---|--|-------|--------------|
| RK109828 [QuickScreen] | 04/04/2022 08:09 AM – 04/06/2022 02:50 PM | on bookshelf behind desk, Library | First | < 0.7 pCi/L |
| RK110450 [QuickScreen] | 04/04/2022 08:09 AM – 04/06/2022 02:36 PM | desk under TV, E102 | First | < 0.9 pCi/L |
| RK110389 [QuickScreen] | 04/04/2022 08:09 AM – 04/06/2022 02:36 PM | on front desk by greetin gwindow, "Main office, main area" | First | < 0.7 pCi/L |
| RK110387 [QuickScreen] | 04/04/2022 08:09 AM – 04/06/2022 02:36 PM | paper towel holder, E103V | First | < 1.1 pCi/L |

Comment to the results

This report replaces 6352561:2. Reason: new or corrected measurement information has been received.

Tryggve Rönqvist (Electronically signed)

Signature Radonova Laboratories Laboratory Measurement Specialist

This report may only be reproduced in full, unless issuing laboratory has given prior written approval.

DISCLAIMER

Radonova Inc. makes no warranty of any kind, express or implied, as regard to the use, operation or analysis of any Radonova Inc. monitor. Radonova Inc. specifically disclaims implied warranties of merchantability and fitness for a particular purpose. Radonova Inc. is not responsible for any damage, including consequential damages, to persons or property resulting from the use of the monitor or the resulting data.

RADONOVA INC.

1 EAST 22nd STREET, SUITE 200
LOMBARD, IL 60148
331.814.2200, help@radonova.com

PBS Portland
4321 S Corbett Ave

OWN ID
N/A
BY
PBS Engineering & Environmental

REPORT RECEIVER(S)
alex.johnson@pbsusa.com;lindsey.peterson@pbsusa.com
PBS Portland

RADON MONITORING REPORT

Description of the measurement

The measurement was performed with an Activated Charcoal Adsorption detector (QuickScreen) and was analyzed by Alpha Energy Laboratories (NRPP ID: 101132 AL).

The detector(s) arrived to Alpha Energy Laboratories, Inc. **04/12/2022**.
They were measured **04/12/2022**.

Test data have been given by PBS Portland

Property data and address

MEASURE SITE ADDRESS
Lakeridge MS
4700 Jean Road
Lake Oswego OR

BUILDING ID

| DETECTOR | MEASUREMENT PERIOD | DESCRIPTION / LOCATION | FLOOR | RADON RESULT |
|------------------------|---|--|-------|--------------|
| RK110381 [QuickScreen] | 04/04/2022 08:09 AM – 04/06/2022 02:36 PM | top of black bookshelf, E103A | First | < 0.9 pCi/L |
| RK109859 [QuickScreen] | 04/04/2022 08:09 AM – 04/06/2022 02:35 PM | top of black bookshelf, E103B | First | < 1.1 pCi/L |
| RK109850 [QuickScreen] | 04/04/2022 08:18 AM – 04/06/2022 02:38 PM | top of black bookshelf, E103C | First | < 1.0 pCi/L |
| RK110441 [QuickScreen] | 04/04/2022 08:18 AM – 04/06/2022 02:39 PM | "admin. workroom, top of cabinet", E103Q | First | < 0.9 pCi/L |
| RK110464 [QuickScreen] | 04/04/2022 08:18 AM – 04/06/2022 02:39 PM | top of brown bookshelf, E103D | First | < 0.9 pCi/L |
| RK109815 [QuickScreen] | 04/04/2022 08:18 AM – 04/06/2022 02:40 PM | on desk, E103E | First | < 0.9 pCi/L |
| RK105155 [QuickScreen] | 04/04/2022 08:24 AM – 04/06/2022 02:46 PM | on table, E103H | First | DNR |
| RK110446 [QuickScreen] | 04/04/2022 08:24 AM – 04/06/2022 02:47 PM | on table, E103J | First | < 0.7 pCi/L |

Comment to the results

This report replaces 6352561:2. Reason: new or corrected measurement information has been received.

Trygve Rönqvist (Electronically signed)

Signature Radonova Laboratories Laboratory Measurement Specialist

This report may only be reproduced in full, unless issuing laboratory has given prior written approval.

DISCLAIMER

Radonova Inc. makes no warranty of any kind, express or implied, as regard to the use, operation or analysis of any Radonova Inc. monitor. Radonova Inc. specifically disclaims implied warranties of merchantability and fitness for a particular purpose. Radonova Inc. is not responsible for any damage, including consequential damages, to persons or property resulting from the use of the monitor or the resulting data.

RADONOVA INC.

1 EAST 22nd STREET, SUITE 200
LOMBARD, IL 60148
331.814.2200, help@radonova.com

PBS Portland
4321 S Corbett Ave

OWN ID
N/A
BY
PBS Engineering & Environmental

REPORT RECEIVER(S)
alex.johnson@pbsusa.com;lindsey.peterson@pbsusa.com
PBS Portland

RADON MONITORING REPORT

Description of the measurement

The measurement was performed with an Activated Charcoal Adsorption detector (QuickScreen) and was analyzed by Alpha Energy Laboratories (NRPP ID: 101132 AL).

The detector(s) arrived to Alpha Energy Laboratories, Inc. **04/12/2022**.
They were measured **04/12/2022**.

Test data have been given by PBS Portland

Property data and address

MEASURE SITE ADDRESS
Lakeridge MS
4700 Jean Road
Lake Oswego OR

BUILDING ID

| DETECTOR | MEASUREMENT PERIOD | DESCRIPTION / LOCATION | FLOOR | RADON RESULT |
|------------------------|---|------------------------------|-------|--------------|
| RK109845 [QuickScreen] | 04/04/2022 08:24 AM – 04/06/2022 02:47 PM | on bookshelf, E103K | First | < 0.7 pCi/L |
| RK110388 [QuickScreen] | 04/04/2022 08:24 AM – 04/06/2022 02:48 PM | on bookshelf, E103L | First | < 0.7 pCi/L |
| RK110396 [QuickScreen] | 04/04/2022 08:24 AM – 04/06/2022 02:51 PM | on desk, E103M | First | DNR |
| RK109796 [QuickScreen] | 04/04/2022 08:24 AM – 04/06/2022 02:51 PM | desk under TV, E103N | First | 0.9 pCi/L |
| RK109791 [QuickScreen] | 04/04/2022 08:24 AM – 04/06/2022 02:51 PM | on paper towel holder, E103P | First | < 0.8 pCi/L |
| RB102790 [QuickScreen] | 04/04/2022 08:23 AM – 04/06/2022 02:41 PM | E103F, on bookshelf by door | First | < 1.4 pCi/L |
| RB104620 [QuickScreen] | 04/04/2022 08:24 AM – 04/06/2022 02:52 PM | Field Blank | First | < 1.1 pCi/L |
| RB104830 [QuickScreen] | 04/04/2022 08:23 AM – 04/06/2022 02:41 PM | E103F, on bookshelf by door | First | < 1.1 pCi/L |

Comment to the results

This report replaces 6352561:2. Reason: new or corrected measurement information has been received.

Trygve Rönqvist (Electronically signed)

Signature Radonova Laboratories Laboratory Measurement Specialist

This report may only be reproduced in full, unless issuing laboratory has given prior written approval.

DISCLAIMER

Radonova Inc. makes no warranty of any kind, express or implied, as regard to the use, operation or analysis of any Radonova Inc. monitor. Radonova Inc. specifically disclaims implied warranties of merchantability and fitness for a particular purpose. Radonova Inc. is not responsible for any damage, including consequential damages, to persons or property resulting from the use of the monitor or the resulting data.

RADONOVA INC.

1 EAST 22nd STREET, SUITE 200
LOMBARD, IL 60148
331.814.2200, help@radonova.com

PBS Portland
4321 S Corbett Ave

RADON MONITORING REPORT

Description of the measurement

The measurement was performed with an Activated Charcoal Adsorption detector (QuickScreen) and was analyzed by Alpha Energy Laboratories (NRPP ID: 101132 AL).

The detector(s) arrived to Alpha Energy Laboratories, Inc. **04/12/2022**.
They were measured **04/12/2022**.

Test data have been given by PBS Portland

Property data and address

MEASURE SITE ADDRESS

Lakeridge MS
4700 Jean Road
Lake Oswego OR

BUILDING ID

| DETECTOR | MEASUREMENT PERIOD | DESCRIPTION / LOCATION | FLOOR | RADON RESULT |
|------------------------|---|------------------------------|-------|--------------|
| RB104881 [QuickScreen] | 04/04/2022 08:24 AM – 04/06/2022 02:52 PM | field blank | First | < 1.7 pCi/L |
| RB104883 [QuickScreen] | 04/04/2022 08:24 AM – 04/06/2022 02:52 PM | E103P, on paper towel holder | First | < 1.6 pCi/L |
| RB104889 [QuickScreen] | 04/04/2022 08:24 AM – 04/06/2022 02:52 PM | field blank | First | < 1.5 pCi/L |
| RB105240 [QuickScreen] | 04/04/2022 08:24 AM – 04/06/2022 02:46 PM | E103T, on bookshelf | First | < 1.2 pCi/L |

Comment to the results

This report replaces 6352561:2. Reason: new or corrected measurement information has been received.

Trygve Rönqvist (Electronically signed)

Signature Radonova Laboratories Laboratory Measurement Specialist

This report may only be reproduced in full, unless issuing laboratory has given prior written approval.

DISCLAIMER

Radonova Inc. makes no warranty of any kind, express or implied, as regard to the use, operation or analysis of any Radonova Inc. monitor. Radonova Inc. specifically disclaims implied warranties of merchantability and fitness for a particular purpose. Radonova Inc. is not responsible for any damage, including consequential damages, to persons or property resulting from the use of the monitor or the resulting data.

RADONOVA INC.

1 EAST 22nd STREET, SUITE 200
LOMBARD, IL 60148
331.814.2200, help@radonova.com

Measurement method: Activated Charcoal Adsorption

For this method using the QuickScreen detector, the airtight container with activated charcoal is opened in the area to be sampled and radon in the air adsorbs onto the charcoal granules. At the end of the sampling period, the container is sealed and may be sent to a laboratory for analysis. The gamma decay from the radon adsorbed to the charcoal is counted on a scintillation detector and a calculation based on calibration information is used to calculate the radon concentration at the sample site.

Measured radon concentrations

For each detector, the measured value of the radon concentration is provided. For each value an uncertainty associated with the measurement to a 95% confidence level is also provided. For example a measurement result of 4.0 ± 0.5 pCi/L means that the radon concentration is most likely contained in the range 3.5 - 4.5 pCi/L. If the start or end date of the measurement has not been provided, the radon concentration cannot be calculated. In such cases, the total exposure in pCi*days/L will be reported. The reported measured values are related to the detectors as received by Radonova Laboratories. Detector deployment is not performed by Radonova Laboratories. Measurement information such as monitoring period (dates) and placement location is provided to Radonova Laboratories by the end user.

Codes on non-reportable detectors

| | |
|------------|--------------------------------------|
| DNR | Not Reported – Detector Not Returned |
| ERR | Not Reported – See comment |

Radon measurements in Multifamily Buildings, Schools and Large Buildings

The United States Environmental Protection Agency (EPA) recommends remediation if the results of one long-term test or the average of two short-term tests conducted in an occupied room are 4.0 pCi/L or higher. The average yearly residential indoor radon level in the US is estimated to be around 1.3 pCi/L. Long-term tests are conducted for more than 90 days. Short-term tests are conducted between 2 and 90 days and should be performed under closed building conditions.

If an initial short-term test result is less than 4 pCi/L, a follow-up measurement is probably not needed.

If an initial short-term test result is between 4 pCi/L and 8 pCi/L, a long-term or a short-term follow-up measurement is recommended.

If an initial short-term test result is greater than 8 pCi/L, a short term follow-up measurement is recommended in order to get a fast result.

More information about radon measurements and mitigation can be found in the AARST and EPA publications:

- ANSI/AARST Protocol for Conducting Measurements of Radon and Radon-Decay Products in Schools and Large Buildings.
- ANSI/AARST Protocol for Conducting Radon and Radon Decay Product Measurements in Multifamily Buildings.
- ANSI/AARST Radon Mitigation Standards for Schools and Large Buildings.
- ANSI/AARST Radon Mitigation Standards for Multifamily Buildings.
- EPA Radon Measurements in Schools, EPA 402-R-92-014, July 1993.

For more information about the interpretation of your test results or about other radon related issues we suggest contacting your state radon office.

Signature on the report

With the signature on the report, the Measurement specialist at Radonova Laboratories certifies that the quality control procedures follows the guidance in accordance with EPA 402-R-95-012. Measurement information displayed in italics on report has been provided by the customer.

Certification no:

101132-AL, 107830-RT, NY ELAP ID: 11430

DISCLAIMER

Radonova Inc. makes no warranty of any kind, express or implied, as regard to the use, operation or analysis of any Radonova Inc. monitor. Radonova Inc. specifically disclaims implied warranties of merchantability and fitness for a particular purpose. Radonova Inc. is not responsible for any damage, including consequential damages, to persons or property resulting from the use of the monitor or the resulting data.

RADONOVA INC.

1 EAST 22nd STREET, SUITE 200
LOMBARD, IL 60148
331.814.2200, help@radonova.com